



City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

DESIGN HYDROLOGY SECTION
123 Central NW, Albuquerque, NM 87102
(505) 766-7644

May 10, 1984

Ray Harrison
Ray Harrison and Associates
1517 A Girard NE
Albuquerque, NM 87106

RE: MCKINNEY GARGAGE ADDITION H21-D-21

Dear Mr. Harrison:

The referenced drainage plan dated May 8, 1984, is approved.

Sincerely yours,

Fred J. Aguirre
Fred J. Aguirre
Design Hydrologist

FJA/dlw

MUNICIPAL DEVELOPMENT DEPARTMENT

C. Dwayne Sheppard, P.E., City Engineer

ENGINEERING DIVISION

Telephone (505) 766-7467

AN EQUAL OPPORTUNITY EMPLOYER

INFORMATION SHEET

GARAGE ADDITION FOR

PROJECT TITLE McKinney Motor Company TYPE OF SUBMITTAL Drainage Plan

ZONE ATLAS PAGE NO. H 21 CITY ADDRESS 1836 Eutank NE 87

LEGAL DESCRIPTION Lot 1A Block 124 Snow Heights Addition

ENGINEERING FIRM Ray Harrison & Associates CONTACT Ray Harrison

ADDRESS 1517 A Girard NE PHONE Albuquerque, NM 87106

OWNER Eunice McKinney CONTACT Same

ADDRESS ~~McKinney~~ 1314 Wyoming NE PHONE 298 6734

ARCHITECT None CONTACT _____

ADDRESS _____ PHONE _____

SURVEYOR Ray Harrison CONTACT _____

ADDRESS _____ PHONE _____

CONTRACTOR Paul Slayton CONTACT same

ADDRESS Box 35155 PHONE 298 5773

PRE-DESIGN MEETING:


- ☒ YES
☐ NO
☒ COPY OF CONFERENCE RECAP SHEET PROVIDED

PLEASE CHECK TYPE OF APPROVAL EXPECTED WITH THIS SUBMITTAL:

- ☐ SKETCH PLAT APPROVAL
☐ PRELIMINARY PLAT APPROVAL
☐ SITE DEVELOPMENT PLAN APPROVAL
☐ FINAL PLAT APPROVAL
☒ BUILDING PERMIT APPROVAL
☐ CERTIFICATE OF OCCUPANCY APPROVAL
☐ ROUGH GRADING PERMIT APPROVAL
☐ GRADING/PAVING PERMIT APPROVAL
☐ OTHER _____ (SPECIFY)

DATE SUBMITTED: 4/24/36

BY: Me





CITY OF ALBUQUERQUE
MUNICIPAL DEVELOPMENT DEPARTMENT
ENGINEERING DIVISION



HYDROLOGY SECTION PROJ. NO. H-21 DATE: 4/13/84

PLANNING DIVISION NO. _____

CONFERENCE RECAP

1836 EDWARDS N.E.

SUBJECT: McKinney Garage Add'n.

WHO

REPRESENTING

ATTENDANCE:

Ray Harrison
Billy Goolsby

Approved

FINDINGS: ① Grading & Drainage Plan per
DPM required prior to release of
building permit.
② Site located adjacent to flood
hazard area - Floodproofing is required
(FF established at a min. of 1' above
floodline in Embank) - Match existing
building FF elevation.
③ Discharge to remain as existing

Please provide a copy of recap w/ submittal

The undersigned agrees that the above findings are summarized accurately and are only subject to change if further investigation reveals that they are not reasonable or that they are based on inaccurate information.

SIGNED:

Billy Goolsby

SIGNED:

Ray Harrison

TITLE:

CE/ Hydrology

TITLE:

DATE:

4/13/84

DATE:

4/13/84

H-21-D-21