CITY OF ALBUQUERQUE



December 29, 2004

James Hamill, R.A. 1333 Corporate Dr., Suite 103 Irving, TX 75038

Re: Church's Chicken, 2307 Juan Tabo Blvd NE, Traffic Circulation Layout Architect's Stamp dated 12-21-04 (H21-D48)

Dear Mr. Hamill,

Based upon the information provided in your submittal received 12-27-04, the above referenced plan cannot be approved for Building Permit until the following comments are addressed:

P.O. Box 1293

1. Please refer to all applicable city standards.

2. Please show a vicinity map on the Traffic Circulation Layout.

3. List the number of parking spaces required by the zoning code as well as the proposed number of parking spaces.

Albuquerque

4. For passenger vehicles, the minimum end island radius is 15 feet. Show how vehicles will travel through the drive-thru lane without interfering with adjacent traffic.

New Mexico 87103

5. Check the scale the Traffic Circulation Layout is drawn at.

6. Indicate all existing areas and clearly show what is proposed.

7. Remove the northern drive on Juan Tabo Blvd. It is located too close to the intersection.

www.cabq.gov

8. The sidewalk should be 6 feet in width. Note that the 2-foot overhang is not allowed to encroach on the 6 foot required width of sidewalk.

If you have any questions, you can contact me at 924-3991.


Sincerely,

Wilfred A. Gallegos, P.E.

Traffic Engineer, Planning Dept.
Development and Building Services

C: file

CITY OF ALBUQUERQUE



December 29, 2004

James Hamill, R.A. 1333 Corporate Dr., Suite 103 Irving, TX 75038

Re: Church's Chicken, 2307 Juan Tabo Blvd NE, Traffic Circulation Layout Architect's Stamp dated 12-21-04 (H21-D48)

Dear Mr. Hamill,

Based upon the information provided in your submittal received 12-27-04, the above referenced plan cannot be approved for Building Permit until the following comments are addressed:

P.O. Box 1293

1. Please refer to all applicable city standards.

2. Please show a vicinity map on the Traffic Circulation Layout.

3. List the number of parking spaces required by the zoning code as well as the proposed number of parking spaces.

Albuquerque

4. For passenger vehicles, the minimum end island radius is 15 feet. Show how vehicles will travel through the drive-thru lane without interfering with adjacent traffic.

New Mexico 87103

5. Check the scale the Traffic Circulation Layout is drawn at.

6. Indicate all existing areas and clearly show what is proposed.

7. Remove the northern drive on Juan Tabo Blvd. It is located too close to the intersection.

www.cabq.gov

8. The sidewalk should be 6 feet in width. Note that the 2-foot overhang is not allowed to encroach on the 6 foot required width of sidewalk.

If you have any questions, you can contact me at 924-3991.

Sincerely,

Wilfred A. Gallegos, P.E.

Traffic Engineer, Planning Dept.

Development and Building Services

C: file

DRAINAGE AND TRANSPORTATION INFORMATION SHEET

(REV. 1/28/2003rd)

PROJECT TITLE: CHURCH'D CHICKEN	ZONE MAP/DRG. FILE #: H-ZVD48
DRB #:EPC#:	WORK ORDER#:
LEGAL DESCRIPTION: CITY ADDRESS: 200 JUAN TABO	
ENGINEERING FIRM:ADDRESS:CITY, STATE:	CONTACT:PHONE;ZIP CODE:
OWNER: CHURCH'S CHICKEN ADDRESS: 980 HAMMOND DR., N.E., S CITY, STATE: ATLANTA, GA	ZIP CODE: 00328
ARCHITECT: JAMES M. HAMILL, AIR ADDRESS: 1333 CORP. DR. # 103 CITY, STATE: IRVINCY, TX	CONTACT: BRANDON RENFROW PHONE: 972.714.0420 ZIP CODE: 75038
SURVEYOR: ADDRESS CITY, STATE:	CONTACT:PHONE:ZIP CODE:
CONTRACTOR: ADDRESS:CITY, STATE:	CONTACT:PHONE:ZIP CODE:
CHECK TYPE OF SUBMITTAL:	CHECK TYPE OF APPROVAL SOUGHT:
DRAINAGE REPORT DRAINAGE PLAN 1st SUBMITTAL, REQUIRES TCL or equal DRAINAGE PLAN RESUBMITTAL CONCEPTUAL GRADING & DRAINAGE PLAN GRADING PLAN EROSION CONTROL PLAN ENGINEER'S CERTIFICATION (HYDROLOGY) CLOMR/LOMR TRAFFIC CIRCULATION LAYOUT (TCL) ENGINEERS CERTIFICATION (TCL) ENGINEERS CERTIFICATION (DRB APPR. SITE PLAN) OTHER	SIA / FINANCIAL GUARANTEE RELEASE PRELIMINARY PLAT APPROVAL S. DEV. PLAN FOR SUB'D. APPROVAL S. DEV. PLAN FOR BLDG. PERMIT APPROVAL SECTOR PLAN APPROVAL FINAL PLAT APPROVAL FOUNDATION PERMIT APPROVAL BUILDING PERMIT APPROVAL CERTIFICATE OF OCCUPANCY (PERM.) CERTIFICATE OF OCCUPANCY (TEMP.) GRADING PERMIT APPROVAL PAVING PERMIT APPROVAL WORK ORDER APPROVAL OTHER (SPECIFY)
WAS A PRE-DESIGN CONFERENCE ATTENDED: YES NO COPY PROVIDED	12/27/04)
DATE SUBMITTED: 12/21/04 BY: MM/M \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \	
Requests for approvals of Site Development Plans and/or Subdivision Plats shall be accompanied by a drainage	

submittal. The particular nature, location and scope of the proposed development defines the degree of drainage details.

One or more of the following levels of submittal may be required based on the following:

1. Conceptual Grading and Drainage Plan: Required for approval of Site Development Plans greater than five

2. Drainage Plans: Required for building permits, grading permits, paving permits and site plans less than five

(5) acres.

 \checkmark

3. Drainage Report: Required for subdivisions containing more than ten (10) lots or constituting five (5) acres or more.

Sale of plan?

Etholisto exists or proposedly stratus, ate

15' minadio

Totroutrow vehicles go get through direthru

spaces regired

6' or side walk reg.

Elefento City Std

* Close nother dire on Juan Tafor - too close to interestion

