



## City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

1:22 - D26

September 28, 1982

Mr. Tom Mann  
Tom Mann & Associates  
811 Dallas N.E.  
Albuquerque, N.M. 87110


RE: VAUGHAN COMPANY OFFICE BUILDING DRAINAGE PLAN

Dear Tom:

I am in general agreement with the proposed drainage scheme for the referenced project. However, I am abit concerned about the proximity of the entrance way to the arroyo crossing. As you know, this particular reach of the channel will not be improved under the East Arroyos V Contract. Therefore, it maybe appropriate to provide some bank protection to insure the integrity of the entrance way.

I point this out as a potensial problem. Please give me a call to discuss the situation.

Very truly yours,

  
Brian G. Burnett  
Civil Engineer/Hydrology

BGB/tsl

MUNICIPAL DEVELOPMENT DEPARTMENT

Richard S. Heller, P.E., City Engineer

ENGINEERING DIVISION

Telephone (505) 766-7467

AN EQUAL OPPORTUNITY EMPLOYER