

CITY OF ALBUQUERQUE



August 31, 2017

J. Graeme Means, PE
High Mesa Consulting Group
6010 –B Midway Park Blvd NE
Albuquerque, NM 87109

**Re: Onate E. S. Classroom Building
12415 Brentwood Hills NE
Request 30-Day Temporary C.O. – Accepted
Engineer's Stamp dated: 11/19/2015 (H22D035)
Certification dated: 8-25-17**

Dear Mr. Means

Based on the Certification received 8/25/2017, the above referenced is approved for a 30-day Temporary Release of Occupancy by Hydrology. However, before a permanent CO can be accepted the following comments must be addressed:

PO Box 1293

- Opening at grade in Mechanical Yard wall is missing
- 6" roof drain embedded in concrete rundown
- Water quality basin at SW corner not complete
- Inlet at SW corner does not appear to be constructed at flowline

Albuquerque

An inspection by our office will need to take place after these corrections are made.

NM 87103

If you have any questions, you can contact me at 924-3986 or Totten Elliott at 924-3982.

www.cabq.gov

Sincerely,

James D. Hughes, P.E.
Principal Engineer, Planning Dept.
Development and Review Services

TE/JH

C: email Serna, Yvette M.; Fox, Debi; Tena, Victoria C.; Sandoval, Darlene M.