

# CITY OF ALBUQUERQUE



March 31, 2016

David Soule, P.E.  
Rio Grande Engineering  
9171 Glendale Ave NE  
Albuquerque, NM 87122

**Re: Indian Ridge Townhomes  
Erosion and Sediment Control Plan  
Engineer's Stamp Date 3-24-16 (H22E078)**

Dear Mr. Soule,

Based upon the information provided in your submittal received 3-24-16 the above referenced plan is approved to be included in the SWPPP and for ESC Permit for grading and Building Permit with the condition:

A mulch sock or alternative acceptable sediment BMP be installed along the west property line.

If you have any questions, you can contact me at 924-3420.

PO Box 1293

Albuquerque

New Mexico 87103

[www.cabq.gov](http://www.cabq.gov)

Sincerely,

Curtis Cherne, P.E.  
Principal Engineer, Stormwater Quality  
Planning Dept.

C: email, [Jeff@inspectionsplus.com](mailto:Jeff@inspectionsplus.com)