

Tim Eichenberg, Chairman  
Danny Hernandez, Vice Chairman  
Bruce M. Thomson, Secretary-Treasurer  
Ronald D. Brown, Assistant Secretary-Treasurer  
Daniel F. Lyon, Director

Jerry M. Lovato, P.E.  
Executive Engineer



**Albuquerque  
Metropolitan  
Arroyo  
Flood  
Control  
Authority**

2600 Prospect N.E., Albuquerque, NM 87107  
Phone: (505) 884-2215 Fax: (505) 884-0214  
Website: [www.amafca.org](http://www.amafca.org)

March 21, 2012

Mr. Jeff Mulberry, P.E., LEED AP BD+C  
Bohannon Huston, Inc.  
7500 Jefferson St. NE, Courtyard I  
Albuquerque, NM 87109

Re: Drainage Management and Construction Plans for APS Community Stadium  
Engineer's Seal Dated 3-12-12

Dear Mr. Mulberry:

I have reviewed your response letter, dated March 7, 2012, and the revised plans and have the following additional comments:

1. On Sheet DMP-002, change the reference to DAR Basin UD.4D to UD.4A.
2. Your response to the impact on the storage volume of Ladera Dam 3 from additional drainage area is noted; however, I would like to see additional clarification. Was the storm drain system analyzed in an AHYMO model? If so, provide a comparison of the volume of flow from SD-43 outfall to the flow volume from DAR Basin UD.3. If not, estimate the volume of flow in SD-43 for comparison.

If you have any questions, please call me at 884-2215.

Sincerely,  
AMAFCA

Lynn M. Mazur, P.E., C.F.M.  
Development Review Engineer

C: Curtis Cherne, COA Development & Bldg Services