



City of Albuquerque Stormwater Construction Site Inspection Report

General Information

Project Name:	Inspirations				
Location:	Arroyo Vista & High Mesa				
Site Contact Name & Agency	Brian A. Pulte Homes	ESC File No.	J08E005		
	brian.anderson@pultegroup.com	NPDES Id. No.	NMR10024T		
Inspection Date:	09/05/19	Start/End Time:	1040/1050hrs		
CoA Stormwater Inspector:	Timothy E. Sims				
Construction Phase:	earthwork				
Type of Inspection:	<input checked="" type="checkbox"/> Regular	<input type="checkbox"/> Storm Event	<input type="checkbox"/> Post Storm Event >0.25"	<input type="checkbox"/> 311/Complaint	<input type="checkbox"/> Follow Up

Weather at time of inspection?	Clear	Temperature: ~	82*
Estimated date of last storm 0.25" or greater	7/7/2019		

Item Number	Deficiency/ Corrective Action		
	no issues observed with this inspection		
	Please provide latest SWPPP self-inspection report.		
2.1	Discharge off site? (Y/N)	No	
4	Self Inspection Reports	requested	Latest report Date: 7/16/2019

Notes:	**Thanks for sweeping track out daily. If track out becomes an issue, a trackout pad may be necessary.

City of Albuquerque Stormwater Inspector Signature and date:
Contact information: Timothy E. Sims - (505) 803-6155
tsims@cabq.gov 09/05/19