



# City of Albuquerque Stormwater Construction Site Inspection Report

## General Information

Project Name:	Inspirations				
Location:	Arroyo Vista & High Mesa				
Site Contact Name & Agency	Brian A. Pulte Homes	ESC File No.	J08E005		
	<a href="mailto:brian.anderson@pultegroup.com">brian.anderson@pultegroup.com</a>	NPDES Id. No.	NMR10024T		
Inspection Date:	05/06/20	Start/End Time:	0945/1030hrs		
CoA Stormwater Inspector:	Timothy E. Sims				
Construction Phase:	infrastructure				
Type of Inspection:	<input checked="" type="checkbox"/> Regular	<input type="checkbox"/> Storm Event	<input type="checkbox"/> Post Storm Event >0.25"	<input type="checkbox"/> 311/Complaint	<input type="checkbox"/> Follow Up

Weather at time of inspection?	Cloudy	Temperature: ~	59*
Estimated date of last storm 0.25" or greater	4/13/2020		

Item Number	Deficiency/ Corrective Action		
	no issues observed with this inspection		
	***Please send the latest SWPPP self-inspection report.***		
	Discussions with Pulte in the field reveal "prairie building" for this site. Please provide sediment BMP's for the roadway and site during this phase. (i.e. compacted dirt berms, mulch socks or equal sediment BMP)		
2.1	Discharge off site? (Y/N)	No	
4	Self Inspection Reports	requested	Latest report Date:

Notes:	**Thanks for sweeping track out daily. If track out becomes an issue, a trackout pad may be necessary.

City of Albuquerque Stormwater Inspector Signature and date:  
Contact information: Timothy E. Sims - (505) 803-6155  
[tsims@cabq.gov](mailto:tsims@cabq.gov) 05/06/20