



City of Albuquerque Stormwater Construction Site Inspection Report

General Information

ESC File No.	J08E005	Project Name:	Inspiration
NPDES Id. No.	NMR10024T	Location:	Arroyo Vista Blvd. and High Mesa Drive
4/22/2021	Owner	Contractor	
Operator	Pulte Homes	Pulte Homes	
Contact name & title	Kevin Patton	Brian Anderson	
e-mail	kevin.patton@pultegroup.com	brian.anderson@pultegroup.com	
Contact Phone #	505-341-8591		
COA Inspector	Thomas Evans	Start/End Time:	2:20 PM/3:20 PM
Construction Phase:	infrastructure		
Type of Inspection:	Regular	Storm Event	Past Storm Event >0.25"
		311/Complaint	Follow Up
Weather at time of inspection?	clear	Temperature:	~ 68
Estimated date of last storm 0.25" or greater	2/22/2021		
Item Number	Deficiency/ Corrective Action		
1	Remove sediment from the streets		
2	Maintain inlet protection		
3	Dispose of construction and domestic waste		
4			
5			
2.1	Discharge off site? (Y/N)	no	
4	Self Inspection Reports	Requested	Latest report Date:

Notes:	The containers were being emptied during this inspection. Great use of pools for washout.
	No washout noted in the lots.

City of Albuquerque Stormwater Inspector Signature and date:
 Contact information: Thomas Evans (505-803-6215)
tevans@cabq.gov

Thomas Evans 04/26/2021