

**NOTE: 2016 Protocol - Maximum
of one SSWR per permit**

PROPRIETARY COMPANY MATERIAL



Date & Time : **06-17-2021 at 12:26 PM**

**NATIONAL STORM WATER QUALITY PROGRAM
SITE INSPECTION REPORT (SIR)**

For use on most PulteGroup Sites as of 01/01/2016

Community Name: Pulte: Inspiration, Arroyo Vista Blvd and Mesa Drive, Albuquerque, NM 87120 NPDES: NMR10024T
(Include Site Name, City, State, Zip Code and NPDES/Construction Storm Water Permit Number)

Master Site List ID: A1414 Inspection performed by: Joshua Armijo , Inspector, Green Globe Environmental
(Print Name, Company, and Title / Qualifications)

Stages of Construction: (check all that apply) ☐ Land Development ☐ Inactive ☐ Vertical Construction ☐ Post-Construction
☒ Land and Vertical
Type of Inspection: (check all that apply) ☒ Routine Inspection ☐ Storm-Event Related ☐ Final Site Inspection
☐ Other:

I. SWPPP - Respond to all Questions

<u>Item</u>		<u>Yes</u>	<u>No</u>	
A	Was the SWPPP accessible at the time of the inspection?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	If "No," then an Action Item is required. Describe all Action Items on the reverse side of this sheet. (Section IV)
B	Is the SSWR correctly identified in the SWPPP?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
C	Does the SWPPP reflect the current stage of development?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
D	Have all SIR action Items identified on the preceding reports been resolved?	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
E	Is NSQP Signage posted and in compliance with NSQP requirements?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

II. Estimated date of most recent Storm Event That triggered an Inspection: 07-25-2020

Provide rainfall information as required by the Applicable Permit: .75

(Base on the storm-event related Inspection Frequency required by the Applicable Permit)

III. Site BMP Inspection

<u>Item</u>	<u>SWPPP Items</u>	<u>Not Applicable</u>	<u>Acceptable</u>	<u>Action Item</u>	<u>Assigned To</u>
Erosion Control					
1	Protection of Disturbed Areas	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	_____
2	Slope Protection	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	_____
3	Vegetation / Revegetation	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	_____
4	Velocity Reduction Devices / Outlet Protection	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	_____
Sediment Control					
5	Check Dams (rock, gravel, other)	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	_____
6	Silt Fence	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	_____
7	Berms, Dikes, Straw Wattles	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	_____
8	Detention Basins/Sediment Traps	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	_____
9	Stockpiles Protected/Stabilized	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	_____
10	Storm Water Inlet Protection	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	_____
Housekeeping / Trade Compliance					
11	Waste and Trash Management	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Pulte
12	Spill and Leak Prevention	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	_____
13	Sanitary Stations	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	_____
14	Concrete and Construction Washouts	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Pulte
15	Material Use and Potential Contaminate Storage	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	_____
16	Equipment Storage and Maintenance	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	_____
17	Construction Exits and Entrances	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	_____
18	Dust Control	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	_____
19	Street Sweeping	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Pulte

PROPRIETARY COMPANY MATERIAL

<u>Item</u>	<u>SWPPP Items (continued)</u>	<u>Not</u> <u>Applicable</u>	<u>Acceptable</u>	<u>Action Item</u>	<u>Assigned To</u>
20	Non-Storm Water Flow	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
21	Site's Weathering of Storm Events	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
22	Site Discharge Points	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
23	BMP Provider Performance	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	

IV. Action Items


V. Responsive Action Completion

<u>Item</u>	<u>Location and Responsive Action to be taken</u>	<u>Date Noted</u>	<u>Date of Completion</u>	<u>Initials</u>
8	Deficiency Name: 11800 beaver mountain Corrective Action: Cutback curb	06-17-2021		
8	Deficiency Name: 11804 beaver mountain Corrective Action: Cutback curb	06-17-2021		
8	Deficiency Name: 11808 beaver mountain Corrective Action: Cutback curb	06-17-2021		
8	Deficiency Name: 11812 Corrective Action: Cutback curb	06-17-2021		
8	Deficiency Name: 11816 beaver mountain Corrective Action: Cutback curb	06-17-2021		
8	Deficiency Name: Echo valley Corrective Action: Cutbacks throughout street	06-17-2021		
11	Deficiency Name: 1705 beaver Mountain Corrective Action: Contain construction debris on the lot	05-27-2021		
11	Deficiency Name: 1798 beaver mountain Corrective Action: Contain construction debris on the lot	05-27-2021		
14	Deficiency Name: 1616 beaver Mountain Corrective Action: Concrete washout pool needs to be cleaned up	05-27-2021		
14	Deficiency Name: 1604 cooper mountain Corrective Action: Concrete washout pool needs to be cleaned up	05-27-2021		
19	Deficiency Name: Beaver mountain Corrective Action: Sweep street	05-27-2021		
19	Deficiency Name: Cooper mountain Corrective Action: Sweep street	05-27-2021		
19	Deficiency Name: Heavenly way Corrective Action: Sweep street	05-27-2021		
19	Deficiency Name: Badger mountain Corrective Action: Sweep street	05-27-2021		
19	Deficiency Name: Mammoth way Corrective Action: Sweep street	05-27-2021		
19	Deficiency Name: Alpine meadows Corrective Action: Street sweeping	06-17-2021		

Attach additional sheet(s) of SIR addendum if necessary

SIR must be reviewed and signed below by SSWR - Not Delegable: I certify under penalty of law that Sections I-V of this document and all attachments were prepared by me or under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gathered and evaluated the information submitted. Based on my inquiry of the persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. In the event there are no Action Items in this report that have remained unresolved for a period in excess of that allowed by the Applicable Construction General

Permit, I further certify under penalty of law that this Site is in compliance with the SWPPP and the Applicable Construction General Permit. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment for knowing violations. Certification applies to the area under the supervision of the SSWR signing this report.

Certified By: (SSWR - Must be a PulteGroup Employee)		Certified By: (Third Party Inspector if required by the Applicable Permit)	
		Joshua Armijo	
Site Storm Water Representative - Print Name and Title		Inspector - Print Name	
			
Site Storm Water Representative Signature (Use Ink)	Date	Inspector Signature (Use Ink)	Date

VI. Justification for non-completion of Responsive Actions
Describe why any Responsive Actions were not corrected within the permit required time period (if applicable).

N/A

Attach additional sheet(s) if necessary

Sediment Control Deficiency Photos



Deficiency Name: 11800 beaver mountain

Corrective Actions: Cutback curb

Sediment Control Deficiency Photos



Deficiency Name: 11804 beaver mountain

Corrective Actions: Cutback curb

Sediment Control Deficiency Photos



Deficiency Name: 11808 beaver mountain

Corrective Actions: Cutback curb

Sediment Control Deficiency Photos



Deficiency Name: 11812

Corrective Actions: Cutback curb

Sediment Control Deficiency Photos



Deficiency Name: 11816 beaver mountain

Corrective Actions: Cutback curb



Deficiency Name: Alpine meadows

Corrective Actions: Street sweeping