

CITY OF ALBUQUERQUE



March 7, 2019
Ron Bohannon, P.E.
Tierra West, LLC
5571 Midway Park Pl NE
Albuquerque, NM 87109

**Re: Brunacini Warehouse
Erosion and Sediment Control Plan
Engineer's Stamp Date 2-5-19 (J10E002G)**

Dear Mr. Bohannon,

Based upon the information provided in your submittal received 3-1-19, the above referenced plan is approved to be included in the SWPPP and for NOI documentation review for grading and Building Permit with the following note:

A sediment BMP may be required at the entrance(s) on Gallatin Pl where the proposed disturbed area is near/at the street.

Include a copy of the approved plan in the Building Permit set.

If you have any questions, you can contact me at 924-3420.

PO Box 1293

Albuquerque

NM 87103

www.cabq.gov

Sincerely,

Curtis Cherne, P.E.
Principal Engineer, Stormwater Quality
Planning Dept.

C: email