

CITY OF ALBUQUERQUE



July 12, 2019

Angelo Brunacini, GA Brunacini Construction Co Inc, abrunacini@brunacini.com

Site: Brunacini/Gallatin

Re: Drainage Ordinance (14-5-2-1) Violation for Construction Site Waste(s)

Dear Mr. Brunacini,

The following violations were observed at today's inspection.

1. Numerous instances of wash-out not in an acceptable wash-out facility.
2. No acceptable wash-out facility on-site.

Some of the photos are shown below:



Wash-out not in an acceptable wash-out facility.

PO Box 1293

Albuquerque

NM 87103

www.cabq.gov



Wash-out not in an acceptable wash-out facility.

PO Box 1293

Albuquerque

NM 87103

www.cabq.gov



Wash-out not in an acceptable wash-out facility.

**Required Mitigation:**

1. Remove all instances of wash-out not in an acceptable wash-out facility. Have workers use an acceptable wash-out facility in the future.
2. Provide an acceptable wash-out facility on-site.

If violations are not mitigated within 7 days, the property owner is subject to a fine of \$500/day per the City's Drainage Control Ordinance.

If you would like to schedule a follow-up inspection at a day and time of your convenience, prior to 7 days from the date of this letter please let me know.

If you have any questions, you can contact me at 924-3420.

Sincerely,

Curtis Cherne, P.E.
Principal Engineer, Stormwater Quality
Planning Dept.

PO Box 1293

Albuquerque

NM 87103

www.cabq.gov