

City of Albuquerque Stormwater Construction Site Inspection Report

| | | | General I | nformation | 1 | | | |
|--------------------------------|--|-------------------------------|---------------|------------|--------------------------|---------------|-----------|--|
| ESC File No. | J11E | 017 P | Project Name: | | Starbucks | | | |
| NPDES Id. No. | NMR10056V | | ocation: | | 1440 Coors Blvd NW | | | |
| 1, 10, 2020 | | Owner | | | Contractor | | | |
| Operator | | Los Dows, LLC | | | Nieto Custom I | | | |
| Contact na | me & title | Aurthor J Dow | | | Anthoney Gom | | | |
| e-mail | | Dowaj@yahoo.com | | | agomez@nietobuilders.com | | | |
| Contact Phone # | | 350-4477 | | | 331-1788 | | | |
| COA Insp | ector | Doug Hughe | es | | Start/End Time | 4:00 | PM | |
| Constru | ction Phase: | | | Building | under roof | • | | |
| Type of Ir | nspection: | Regular | Storm Event | Past Storm | Event >0.25" | 311/Complaint | Follow Up | |
| Weather at time of inspection: | | nspection? | Clear | | Temperature: ~ 80 | | 80 | |
| Estimated | date of last s | torm 0.25" oı | greater | | 3/16/2023 | | | |
| Item | | | | | | | | |
| | | Deficiency/ Corrective Action | | | | | | |
| Number | | | | | | | | |
| 1 | SWPPP - Self inspection reports were not available on-site. The signed reports must be available on-site | | | | | | | |
| | per CGP 4.7.3, 5.4.3, and 7.3. | | | | | | | |
| 2 | Sediment in Giomi Pl. east of the site must be removed per CGP 2.2.4.d. | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| 2.1 | Discharge off site? | (Y/N) | no | | | | | |
| 4 | Self Inspec | tion Reports | Requested | Latest re | port Date: | None or | n file | |

| N | otes: | |
|----|-------|--|
| I۷ | ULCS. | |

The first inspection and Notice of Violation #1 was sent on 10/31/22 for Posting, SWPPP, NOI, BMPs, and sediment in the street south and east of the site. At the second inspection on 11/8/22, the only progress was removing the sediment from the streets so NOV #2 was sent. At the third inspection on 11/17/22 the only progress was the was NOI filed with the EPA,so NOV #3 was sent for Posting, SWPPP, and BMPs. BMPs were present at the 4th inspection on 12/6/22 but the sign wasn't placed close eneough to the street to read, and the SWPPP wasn't available so NOV #4 was sent. Posted coverage was present at the 5th inspection on 4/10/23, but the SWPPP self-inspection reports were not available at the site, and sediment was in the street east of the site so NOV #5 was sent.

City of Albuquerque Stormwater Inspector Signature and date: 4/11/2023

Contact information: Doug Hughes (505-924-3420)

jhughes@cabq.gov

James D. Hughes