

## City of Albuquerque Stormwater Construction Site Inspection Report

General Information							
Project Name:		Monterey Place Apartments					
Location:		2306-2320 Central Ave SW					
Site Contact Name &		James Mathew		ESC File No.	J12E030		
Agency			pacificap.com	NPDES Id. No.			
Inspection Date:			tart/End Time: 08	25/0900hrs			
Coa Storm	water Inspecto	r: [1	imothy E. Sims	Do	m.a		
	spection: x	Regular	Storm Event	Post Storm E	mo	311/Complaint	Follow Up
Type of it	ispection. X	Regulai	[3toriii Everit]	FOST STOTTILE	vent >0.25	[311/Complaint]	Trollow op
Weather at time of inspection? Clear Temperature: ~ 39*							
Estimated date of last storm 0.25" or greater							
			A. S. S. S.				
Item	Deficiency/ Corrective Action						
Number							
1	Provide NPDES posting for this site. (either NOI or Low Erosivity Wavier, LEW)						
2	Track out pads requires installation						
3	Sediment BMP's along the northside fronting Central require installation. A mulch sock can						
	mitigate this issue.						
4	Please provide the initial SWPPP self-inspection report. This determines the start date to assist						
	with the LEW time frame.						
5	Please provide an approved ESC Plan.						
2.1	Discharge off site?	(Y/N)	No				
4	Self Inspect	tion Reports	requested	Latest rep	ort Date:	not on	file
Notes:							
		•					
	-				•		

City of Albuquerque Stormwater Inspector Signature and date:

Contact information: Timothy E. Sims - (505) 803-6155

<u>tsims@cabq.gov</u> 02/19/20