CITY OF ALBUQUERQUE

Planning Department Brennon Williams, Director



Mayor Timothy M. Keller

January 4, 2021

Jeremy Shell RESPEC 5971 Jefferson St. NE Ste. 101 Albuquerque, NM 87113

RE: Huning Castle 1500 Central Ave SW Grading and Drainage Memorandum Engineer's Memorandum Date: 12/8/2020 Hydrology File: J13D062

Dear Mr. Shell:

PO Box 1293 Based on the memorandum and attached detail received 12/9/20, this is approved for Administrative Amendment Building Permit by Hydrology.

Albuquerque If you have any questions, please contact me at 924-3986 or earmijo@cabq.gov.

NM 87103 Since

Sincerely,

www.cabq.gov Ernest Armijo, P.E. Principal Engineer, Planning Dept. Development Review Services



City of Albuquerque

Planning Department Development & Building Services Division DRAINAGE AND TRANSPORTATION INFORMATION SHEET (REV 11/2018)

Project Title:	Building	Permit #: Hydrology File #:
DRB#:	EPC#:	Work Order#:
Legal Description:		
City Address:		
Applicant:		Contact:
Address:		
		E-mail:
Owner:		Contact:
Address:		
Phone#:	Fax#:	E-mail:
TYPE OF SUBMITTAL: PLAT	(# OF LOTS)	_ RESIDENCE DRB SITE ADMIN SITE
IS THIS A RESUBMITTAL?:	Yes	No
DEPARTMENT: TRAFFIC/ TR	ANSPORTATION	HYDROLOGY/ DRAINAGE
Check all that Apply: TYPE OF SUBMITTAL: ENGINEER/ARCHITECT CERTI PAD CERTIFICATION CONCEPTUAL G & D PLAN GRADING PLAN DRAINAGE MASTER PLAN DRAINAGE REPORT FLOODPLAIN DEVELOPMENT I ELEVATION CERTIFICATE CLOMR/LOMR TRAFFIC CIRCULATION LAYO TRAFFIC IMPACT STUDY (TIS) OTHER (SPECIFY) PRE-DESIGN MEETING?	PERMIT APPLIC UT (TCL)	TYPE OF APPROVAL/ACCEPTANCE SOUGHT: BUILDING PERMIT APPROVAL CERTIFICATE OF OCCUPANCY PRELIMINARY PLAT APPROVAL SITE PLAN FOR SUB'D APPROVAL SITE PLAN FOR BLDG. PERMIT APPROVAL FINAL PLAT APPROVAL SIA/ RELEASE OF FINANCIAL GUARANTEE FOUNDATION PERMIT APPROVAL GRADING PERMIT APPROVAL SO-19 APPROVAL APPROVAL AVING PERMIT APPROVAL GRADING/ PAD CERTIFICATION WORK ORDER APPROVAL CLOMR/LOMR FLOODPLAIN DEVELOPMENT PERMIT

COA STAFF:

ELECTRONIC SUBMITTAL RECEIVED:

FEE PAID:



DRAINAGE MEMORANDUM

То:	Ernest Armijo, PE Principal Engineer, Hydrology City of Albuquerque, Planning
From:	Jeremy Shell, PE Engineer, Community Design Solutions RESPEC
Date:	December 8, 2020
Subject:	Huning Castle Apartments

Dear Mr. Armijo,

The purpose of this memorandum is to address the drainage concerns that arose from the Administrative Amendment (AA) application for the Huning Castle Apartments. The proposed amendment is to add new covered parking structures and bike enclosure along the west side of the property.

Per the section provided with the AA request, storm water that falls on the covered parking will drain from east to west. In order to maintain the existing flow rate and drainage pattern for the site, gutters will be required with the installation of the covered parking structures to direct runoff back into the parking lot. This solution is shown conceptually on Exhibit A attached to this memorandum. Further, there will need to be a minimum clearance of 6" between the bottom of the bike enclosure fence and the top of the existing parking lot grade. This is required so that the flow of site runoff will not be disrupted at this location.

Should you have any questions or additional concerns with the proposed amendment or this drainage memorandum, please do not hesitate to contact me. Your consideration in this matter is appreciated.

5971 JEFFERSON ST., NE SUITE 101 Albuquerque, NM 87109 505.268.2661

Sincerely,

Jeremy Shell, PE **RESPEC** Community Design Solutions 505.918.1053 cell // 505.253.9811 office jeremy.shell@respec.com

