

CITY OF ALBUQUERQUE



August 29, 2013

Jeffrey Mortensen, P.E.
High Mesa Consulting Group
6010-B Midway Park blvd NE
Albuquerque, NM 87109

**Re: Explora Science Center & Children's Museum Addition and Renovations,
1701 Mountain Road NW
Request for 30-day Temporary –Accepted
Engineer's Stamp dated: 6-18-12, (J13D070)
Certification dated: 8-28-13**

Dear Mr. Mortensen,

Based upon the information provided in the certification received 8-28-13, the above referenced certification is acceptable for a release of a 30-day Temporary Certificate of Occupancy (CO) by Hydrology.

PO Box 1293

When submitting for Permanent CO in addition addressing the exceptions listed , please determine if the 2" force main has backflow prevention since the curb flow line elevation is higher than the pond bottom elevation.

Albuquerque

If you have any questions, you can contact me at 924-3986.

New Mexico 87103

Sincerely,

Curtis A. Cherne, P.E.
Principal Engineer, Hydrology Section
Development and Review Services

www.cabq.gov

C: CO Clerk—Katrina Sigala, Francis Connor
File
JMortensen@highmesacg.com
henrye@hbconstruction.com