

Biazar, Shahab

From: Biazar, Shahab
Sent: Sunday, July 20, 2014 9:12 AM
To: Martin J. Garcia (martin@anchoreng.net)
Cc: Ortiz, Monica; Sims, Timothy E.
Subject: Erosion And Sediment Control Plan For Garcia's Kitchen (J13E096)

Hi,

I have the following comments on the submittal for Garcia's Kitchen's Erosion & Sediment Control (ESC) Plan, (J13E096):

- _Sing posting location should be shown on the plan (sign to be visible from public street).
- _All plans should be signed and stamped.
- _Include Legend and Drawing Scale.
- _Show staging and concrete washout area.
- _Include a note that "Project is required to maintain a regiment of street sweeping and clean up measures in the event of track out to minimize and prevent off site conveyances during construction."
- _Include all BMP details on the plan. If BMP details are shown on a separate sheet, please make sure the plan is signed and stamped.

Just a reminder to submit electronic (PDF format) copy of the plan when submitting the hard copy. You can email the PDF files to Monica or Tim prior to your hard copy submittal.

Grading and Drainage Plan must be approved prior to approval of the ESC Plan.

Thanks and have a nice day

Shahab Biazar, P.E.

Acting City Engineer
Planning Department
Development Review Services Division
600 2nd St. NW, Suite 400
Albuquerque, NM 87102
t 505-924-3422
f 505-924-3440