



# City of Albuquerque Stormwater Construction Site Inspection Report

## General Information

Project Name and Location	Garcias Central + Laguna		
Site Contact Name & Agency	Kelley Fuller E2PC	Contact Phone #	505 967-4040
Date of Inspection	2-29-16	Start/End Time	1:10/1:20
Inspector Name, COA Dept.	Curtis Cherne, Stormwater Quality		
Inspector Phone / E-mail	505-924-3420/ccherne@cabq.gov		
Inspector Qualifications	Qualified Compliance Inspector of Stormwater- Stormwater One		
Describe Present Phase of Construction	Stabilized		

## Type of Inspection:

- ☒ Regular    • During storm event    • Post-storm event    • 311 / Complaint Response    • Follow-Up

## Weather Information

### Weather at time of this inspection?

Temperature: ~ 70 F°

- ☒ Clear    • Cloudy    • Rain    • Sleet    • Fog    • Snowing    • Windy

Has there been a storm event since the site was Permitted? • ☒ Yes • NoAmount:    • < 1/4"    • 1/4" to 3/4"    • > 3/4"    • Snow \_\_\_\_\_"

## Erosion & Sediment Control Inspection

### Check any BMPs that have FAILED or REQUIRE MAINTENANCE

- Entrance / Off Tracking NO
- Sediment Controls / Silt Fence, Check Dams, Waddles, etc. NA - slab
- Erosion Controls / Mulch, Seed, landscaped
- Wind Blown Erosion NO
- Debris/Pollutants/Sediment in MS4 NO
- 

Is site being maintained in compliance with the Drainage Ordinance? • ☒ Yes • NoSignature Curtis C. CherneDate 2-29-16



# City of Albuquerque Stormwater Construction Site Inspection Report

## General Information

Project Name and Location	Garcia's Kitchen Central + Laguna	ESC PERMIT #	16
Site Contact Name & Agency	Keiley Fetter P.E. E2PC	Contact Phone #	505-867-9080
Date of Inspection	6-24-15	Start/End Time	10:00/10:15
Inspector Name, COA Dept.	Curtis Cherne, Stormwater Quality		
Inspector Phone / E-mail	505-924-3420/ccherne@cabq.gov		
Inspector Qualifications	Stormwater USA		
Describe Present Phase of Construction	rough graded, bldg near completion		
Type of Inspection:	<input type="checkbox"/> Regular <input checked="" type="checkbox"/> Drive-By/Random <input type="checkbox"/> During storm event <input type="checkbox"/> Post-storm event <input type="checkbox"/> 311 / Complaint Response <input type="checkbox"/> Follow-Up		

## Weather Information

Weather at time of this inspection? ☒ Clear    ☐ Cloudy    ☐ Rain    ☐ Sleet    ☐ Fog    ☐ Snowing    ☐ High Winds    ☐ Other: \_\_\_\_\_  
 Temperature: ~ 85 F°

Has there been a storm event since the site was Permitted? ☒ Yes    ☐ No  
 Amount: ☐ < 1/4"    ☐ 1/4" to 3/4"    ☐ > 3/4"    Intensity: ☐ Light    ☐ Med.    ☐ Hvy.    ☐ Snow \_\_\_\_\_

## Erosion & Sediment Control Inspection

### Check any BMPs that have FAILED or REQUIRE MAINTENANCE

- Entrance / Off Tracking entrance in poor condition, however there is 200' of pavement before Central Ave, no track-out onto Central
- Sediment Controls / Silt Fence, Check Dams, Waddles, etc. OK
- Erosion Controls / Mulch, Seed, OK
- Wind Blown Erosion NO
- Housekeeping / Pollutant Controls concrete sluiceway wash out east side
- concrete wash-out next to station north side, a little drasly

Is site being maintained in compliance with Const. Gen. Permit? Yes ☒ No ☐ Curtis Cherne 6-24-15  
 Signature Date