CITY OF ALBUQUERQUE

Planning Department Alan Varela, Director



Mayor Timothy M. Keller

April 17, 2025

Dan Caruso RMKM Architecture 400 Gold Ave. SW Albuquerque, NM 87102

Re: Explora Brillante ELC

1005 18th St. NW

Traffic Circulation Layout

Engineer's/Architect's Stamp 04-16-25 (J13D218)

TRANS 2025-00079

Dear Mr. Caruso,

The TCL submittal received 04-04-2025 is approved for Building Permit by transportation. A copy of the stamped and signed plan will be needed for each of the building permit plans. Please keep the original to be used for certification of the site for final C.O. for Transportation.

PO Box 1293

When the site construction is completed and an inspection for Certificate of Occupancy (C.O.) is requested, use the original City stamped approved TCL for certification. Redline any minor changes and adjustments that were made in the field. A NM registered architect or engineer must stamp, sign, and date the certification TCL along with indicating that the development was built in "substantial compliance" with the TCL. Submit this certification, and the TCL, to ABQ-PLAN for log in and evaluation by Transportation.

NM 87103

Albuquerque

Once verification of certification is completed and approved, notification will be made to Building Safety to issue Final C.O. To confirm that a final C.O. has been issued, call Building Safety at 924-3690.


www.cabq.gov

Sincerely,

Ernest Armijo, P.E.

Principal Engineer, Planning Dept. Development Review Services

\xxx via: email C: CO Clerk, File





SPECIFICATION KEYED NOTES

32 1313.A1 CONCRETE PAVING
32 3300.A1 BICYCLE RACK

TCL KEYED NOTES

THAT ARE LESS THAN 35' IN WIDTH)

A. LANDSCAPING AND SIGNAGE WILL NOT INTERFERE WITH CLEAR SIGHT REQUIREMENTS. THEREFORE, SIGNS, WALLS, TREES, AND SHRUBBERY BETWEEN 3 AND 8 FEET TALL (AS MEASURE FROM THE GUTTER PAN) WILL NOT BE ACCEPTABLE IN THE CLEAR SIGHT TRIANGLE

COA STD DWG 2446 (NO ADA CURB RAMPS EXIST IN PROJECT, ONLY FLUSH DRIVE PADS

- B. ALL BROKEN OR CRACKED PUBLIC CITY SIDEWALK AND CURB AND GUTTER IN THE
- PROJECT FRONTAGE SHALL BE REPLACED PER COA STD DWGS 2415A AND 2430

	REQUIRED # OF SPACES:	SPACES PROVIDED :
AUTOMOBILE:	40	40
ADA PARKING SPOTS:	2 (1-VAN)	4 (2-VAN)
BIKE:	4	8
MOTORCYCLE:	2	2

OFF-STREET PARKING (VOCATIONAL SCHOOL OCCUPANCY) PER TABLE 5-5-1: 3 SPACES FOR EVERY 1,000 SF OF BUILDING GROSS AREA 13,310 / 1,000 = 13.3 * 3 = 40. ADA PER NMAC 14.7.2.19
BIKE PARKING FOR (DAY CARE USE) PER TABLE 5-5-5 AT 10% = 4
MOTORCYCLE PARKING PER TABLE 5-5-4 = 2

ADDENDUM 3 04/02/2025

NO. ISSUE DATE

PROJECT 7011 95 CITY C

7011.95 CITY OF ALBUQUERQUE
BRILLANTE! EARLY
LEARNING CENTER

SCALE 1" = 20'-0"

RMKM PROJECT NO. 2301 - 7011.95

PROJECT MANAGER ANTONI BACA

1005-B 18th St NW ALBUQUERQUE, NM 87104 MODELED BY

RMKM


SHEET TITLE
TCL SITE PLAN


DESIGN PHASE
100% CONSTRUCTION DOCUMENTS


SHEET NUMBER

ASTCL

























TYP. 4.5" ASPHALT PAVING SECTION

1 1/2" = 1'-0"



GENERAL NOTES:

REFER TO CITY OF ALBUQUERQUE STANDARD 2425A ABD 2458 FOR DRIVEPAD DRAWINGS.
 REFER TO CITY OF ALBUQUERQUE STANDARD 2400 SERIES FOR ADDITIONAL SIDEWALK DRAWINGS.

