



Goldberg - Mann & Associates, Inc.

Engineers - Planners

911 Pennsylvania St., N.E.

Albuquerque, New Mexico 87110

(505) 285-3521

June 27, 1979

9-44

Mr. Bruno Conegliano  
Asst. City Engineer/Hydrology  
Division of Engineering  
P.O. Box 1293  
Albuquerque, New Mexico 87103

RECEIVED

JUN 29 1979

Re: 615 First Street N.W.

CITY ENGINEER

Dear Bruno:

Transmitted herewith are two (2) revised prints of the drainage plan for the Plaza Maya Office Building.

In accordance with your June 18, 1979 letter, we have raised the finished floor elevation to elevation 4955.0. Several of the grades, also, were adjusted to accommodate the higher floor elevation. Also we have added the note to the drawings stating that we do not feel that we have altered the natural drainage pond as shown on the Bohannon-Huston report.

If you have any questions or comments, please do not hesitate to call.

Thank you.

Yours truly,

GOLDBERG-MANN & ASSOCIATES, INC.

  
Thomas T. Mann, Jr., P.E.  
President

TTM:pe

xc: Don Fletcher