



City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

November 30, 1982

Mr. Duane Logan
Geotechnical Research
& Services, LTD
501 Kinley NE
Albuquerque, New Mexico 87102

Re: Industrial Electric Equipment Service Addition - Dated 11/12/82
501 Kinley Avenue SE (File No. J14-D9)

Dear Mr. Logan:

The proposed addition for the referenced site does not address how the 4 foot change in grade along the north property line will be accomplished to maintain the integrity of the existing grade on the abutting property to the north. Also, please provide us with a typical detail or details of the proposed swale along the west side of the proposed addition.

If you have any questions regarding the above, please feel free to call me at 766-7644.

Sincerely,

Fred J. Aguirre, PE
Civil Engineer/Hydrology

FJA/el

cc: Drainage File
Reading File

MUNICIPAL DEVELOPMENT DEPARTMENT

Richard S. Heller, P.E., City Engineer

ENGINEERING DIVISION

Telephone (505) 766-7467

AN EQUAL OPPORTUNITY EMPLOYER