



City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87102

December 10, 1982

Mr. J. W. Bettis
Enchantment Engineering, Inc.
9910 Indian School NE
Albuquerque, New Mexico 87112

Re: Drainage Plan for Lots 9 and 10, Block 2, Trotter Addition,
Dated December 7, 1982


Dear Mr. Bettis:

The referenced plan received December 10, 1982 is being returned for noncompliance with the Drainage Ordinance which requires discharge of the pond.

Please provide a revised plan with provisions for discharge into a public right-of-way as required by the Drainage Ordinance and outlined by the Development Process Manual, Volume 2, Section 22.7.

If you have any questions regarding the above, please feel free to call me at 766-7644.

Sincerely,


Fred J. Aguirre, PE
Civil Engineer/Hydrology

FJA/el

cc: Drainage File
✓ Reading File

MUNICIPAL DEVELOPMENT DEPARTMENT

Richard S. Heller, P.E., City Engineer

ENGINEERING DIVISION

Telephone (505) 765-7467

AN EQUAL OPPORTUNITY EMPLOYER