



City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

J14 - D29

January 28, 1983

Mr. Frank Lovelady
Boyle Engineering
3939 San Pedro NE, Suite D
Albuquerque, N.M. 87110

RE: DRAINAGE PLAN FOR ALBUQUERQUE NATIONAL PARK OPERATIONS CENTER

Dear Frank:

I have taken the liberty of reviewing the report which was originally transmitted to Fred Aguirre. Hopefully, this will not cause a duplication of effort on your part. Following are my comments:

1. Please identify the 100-year ponding limit on the plan.
2. Please call out the orifice plate on Section A-A of the Catch Basin detail.
3. Can the finished floor elevation of the existing building be used as a temporary bench mark?
4. Approved copies of Special Order No. 19 for the storm drain connection must be placed in the City construction sets prior to release of the building permit.

I appreciate the effort in preparing a well thought-out plan. Please call if you have any questions.

Very truly yours,

Brian G. Burnett
Civil Engineer/Hydrology

BGB/tsl

MUNICIPAL DEVELOPMENT DEPARTMENT

Richard S. Heller, P.E., City Engineer

ENGINEERING DIVISION

Telephone (505) 766-7467

AN EQUAL OPPORTUNITY EMPLOYER