

Boyle Engineering Corporation

Suite D
3939 San Pedro N.E.
Albuquerque, New Mexico 87110

consulting engineers

506 / 883-7700

Mr. Brian G. Burnett
Civil Engineer/Hydrology
City of Albuquerque
P.O. Box 1293
Albuquerque, New Mexico 87103

February 3, 1983

RE: DRAINAGE PLAN FOR ALBUQUERQUE
NATIONAL BANK OPERATIONS CENTER
S01-224-18

Dear Brian:

In response to your letter of January 28, 1983, the numbered comments contained therein are answered as follows:

1. The 100-year ponding limit has been identified on the plan.
2. The orifice plate has been called out on Section AA of the catch basin detail. Also, it has been shown to apply only to the southern catch basin.
3. The finished floor elevation of the existing building has been referenced as a temporary bench mark. The south entrance was actually used as a T.B.M.
4. Approved copies of the Special Order No. 19 have been placed in the City construction sets. An approved copy is attached for your information.

Three prints of the revised plan are attached for insertion into the binders you have. If you require any additional information please do not hesitate to contact me.

Sincerely,

BOYLE ENGINEERING CORPORATION


Frank D. Lovelady, P.E.
Senior Civil Engineer

cc: Glenn Fellows - SMPC