



City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

READING FILE

November 23, 1983

Art Montoya
W.C. Kruger and Associates
1100 First Interstate Bank Building
Albuquerque, NM 87102

REF: CITY/COUNTY MUNICIPAL OFFICE BUILDING (J14-D30A)

Dear Mr. Montoya:

The referenced drainage plan has been reviewed and the following are my comments:

1. The inflow discharges to the proposed storm drains (8" CIP, 12" CIP, 15 RCP) indicates the subject S.D.'s will be operating under pressure flow; however, the report makes no provisions for such a condition. Please provide the required hydraulic calculations to evaluate the proposed storm drain system.
- ✓ 2. Provide invert elevations for the storm drain, provide grate and invert elevations for the catch basins.
- ✓ 3. Provide finished floor and basement elevations.
- ✓ 4. The proposed construction within the City's R/W requires a "Construction Within Public R/W" Document. Please include this document with your resubmittal.
- ✓ 5. Include Engineer's stamp with signature and date on the drainage plan.

If you have any further questions or comments on the above referenced site, please feel free to contact me at 766-7644.

Sincerely,

Fred J. Aguirre
Fred J. Aguirre
Design Hydrologist

FJA:mrk

MUNICIPAL DEVELOPMENT DEPARTMENT

C. Dwayne Sheppard, P.E., Acting City Engineer ENGINEERING DIVISION

Telephone (505) 766-7487

AN EQUAL OPPORTUNITY EMPLOYER

BACKWATER
VALVES
IN CONSTRUCTION

ANOTHER
SUBMITTAL