



CITY OF ALBUQUERQUE
MUNICIPAL DEVELOPMENT DEPARTMENT
ENGINEERING DIVISION



HYDROLOGY SECTION PROJ. NO. _____ DATE: 7/28/83

PLANNING DIVISION NO. _____

CONFERENCE RECAP

SUBJECT: 820 1st St N.W.

514-033

WHO	REPRESENTING
ATTENDANCE: _____	_____
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____

RECEIVED
SEP 13 1983
ENGINEERING

FINDINGS:

1. DRAINAGE PLAN REQUIRED, I.E., A SITE PLAN SHOWING
the EXISTING STRUCTURES ON SITE WITH THE PROPOSED DEVELOPMENT
IDENTIFIED ON THE PLAN.
2. SHOW EXISTING ~~DRAINAGE~~ AND PROPOSED DRAINAGE PATTERN
3. IDENTIFY ANY OFF-SITE ~~AND/OR~~ ON-SITE ^(CONNECTIONS) ~~THAT~~ MAY ~~BE~~
ADVERSELY AFFECT PROPOSED DEVELOPMENT OR EXISTING STRUCTURES.
4. RECOMMEND FINISH FLOOR OR ELEVATED ABOVE TOP OF CURB.
PROVIDE MSL ELEVATION TO DEMONSTRATE THIS ~~RE~~ CRITERIA

The undersigned agrees that the above findings are summarized accurately and are only subject to change if further investigation reveals that they are not reasonable or that they are based on inaccurate information.

SIGNED: [Signature]

SIGNED: [Signature]

TITLE: _____

TITLE: Geotech Research

DATE: 7/28/83

DATE: 7/28/83