



City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

September 19, 1983

Mr. Duane Logan
Geotechnical Research & Services, Ltd.
501 Kinley NE
Albuquerque, NM 87102

RE: 820 First Street NW (Dated September 14, 1983)

Dear Mr. Logan:

The referenced drainage plan is approved; however, I would recommend that your client raise the finished floor elevation one (1) foot above the top of the curb in view of the "A0" (Depth 1) zone designation for First Street as identified on the Flood Insurance Rate Maps. The building plans will be signed off with the inclusion of the approved plan in the building set.

If you have any questions regarding the above, please call me at 766-7467.

Very truly yours,

Fred J. Aguirre
Fred J. Aguirre, P.E.
Design Hydrologist

FJA/dw

cc: File

MUNICIPAL DEVELOPMENT DEPARTMENT

Richard S. Heller, P.E., City Engineer

ENGINEERING DIVISION

Telephone (505) 766-7467

AN EQUAL OPPORTUNITY EMPLOYER
