



City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

March 23, 1984

DESIGN HYDROLOGY SECTION
123 Central NW, Albuquerque, NM 87102
(505) 766-7644

Mr. Jake Bordenave
DMJM/Adam, Hamlyn, Anderson
4055 Montgomery Blvd. NE Suite A
Albuquerque, New Mexico 87109

RE: GRADING & DRAINAGE PLAN FOR PARKING LOT FOR NAPA
ALBUQUERQUE FACILITY (J14-D40) RECEIVED MARCH 6, 1984

Dear Jake:

I have reviewed the above referenced plan and forward the following comments:

- ✓ 1. The off-site flows have not been addressed.
- ✓ 2. What is the discharge rate from the site and how will it be achieved? The plan indicates a 4" sidewalk culvert but, there is no further mentioning of it. What is the head on this pipe? I cannot verify if it will work. Where are the emergency spillways? What do they look like?
3. The plan indicates that the site is adjacent to an alley. Approved alley grades are required.
4. The plan should have the legal description on it or the current plat should be provided.
5. An Erosion Control Plan should be provided for the period of construction.

Should you have any questions or comments, please contact me.

Yours truly,

Billy Goolsby, P.E.
City/County Flood Ordinance Administrator

BG/ca

MUNICIPAL DEVELOPMENT DEPARTMENT

C. J. Goolsby, P.E., City Engineer

ENGINEERING DIVISION

TELEPHONE (505) 766-7657

AN EQUAL OPPORTUNITY EMPLOYER