

DMJM/Adam, Hamlyn, Anderson

April 5, 1984
Mr. Billy Goolsby
City of Albuquerque, Hydrology
PO Box 1293
Albuquerque, NM 87103

Re: Grading & Drainage Plan for Parking Lot For NAPA
Albuquerque Facility (J14-D40)

Dear Sir:

The following are answers to your question regarding the subject site.

1. There is no offsite flow entering this site.
2. Peak discharge rate from the site is 0.289 cfs with a maximum head of 0.48 feet and emergency spillways is the Drivepad located at the NW corner of the site.
3. A note has been added to the plans and the site shall not be accessible from the adjacent alley. The existing alley is approximately 1/2 foot above the finish floor of the adjacent building and I would rather not be responsible for setting grades and subjecting myself to the potential liability that could be incurred.
4. Legal description has been added to the plans.
5. A note regarding sequence of construction has been added to the plan, which will affect Erosion Control.

Sincerely,



Jean J. Bordenave, PE

JJB/cc1

