



CITY OF ALBUQUERQUE
MUNICIPAL DEVELOPMENT DEPARTMENT
ENGINEERING DIVISION



HYDROLOGY SECTION PROJ. NO. _____ DATE: 4/13/84

PLANNING DIVISION NO. J14

CONFERENCE RECAP

SUBJECT: S.E. CORNER OF Constitution & 2nd St.
1510 2nd St N.W.

WHO	REPRESENTING
ATTENDANCE: <u>KEN NOVEY</u>	_____
<u>JAKE BARDELAUF</u>	_____
<u>FRED J. AGUIRRE</u>	_____
_____	_____
_____	_____
_____	_____
_____	_____

FINDINGS:

1. DRAINAGE PLAN REQUIRED FOR the proposed improvements
per the DPM
 2. NO ponding REQUIRED SINCE ^{the site} IS PRESENTLY IMPROVED
 3. ESTABLISH the FINISH FLOOR ELEVATION BASED ON
the flooding shown on the FLOODPLAIN MAPS. AO
zone of 2 ft depth.
 4. ADDRESS OFF-SITE FLOWS - OFF-SITE FLOWS MUST
BE ACCEPTED ON-SITE AND ROUTED TO A PUBLIC R/W
 5. ROOF RUNOFF MUST BE ROUTED THRU A DRIVEWAY OR THRU A CURB
CUT IN ACCORDANCE WITH "CONSTRUCTION WITHIN PUBLIC R/W DOCUMENT"
- The undersigned agrees that the above findings are summarized accurately and are only subject to change if further investigation reveals that they are not reasonable or that they are based on inaccurate information.

SIGNED: Fred J. Aguirre

SIGNED: J. P. Bardeauf

TITLE: _____

TITLE: DMJM/AHA

DATE: 4/13/84

DATE: 4/13/84