




CITY OF ALBUQUERQUE  
MUNICIPAL DEVELOPMENT DEPARTMENT  
ENGINEERING DIVISION



HYDROLOGY SECTION PROJ. NO. J14 DATE: 4/25/84

PLANNING DIVISION NO. \_\_\_\_\_

CONFERENCE PECAP

SUBJECT: LOS TOMASES WAREHOUSE  
LOT 3, BLOCK 16 OF THE REDBRIGHT-MOORE ADDN

| WHO                              | REPRESENTING |
|----------------------------------|--------------|
| ATTENDANCE: <u>JEFF MORRISON</u> | _____        |
| <u>RED J. RAUQUE</u>             | _____        |
| _____                            | _____        |
| _____                            | _____        |
| _____                            | _____        |
| _____                            | _____        |
| _____                            | _____        |

FINDINGS:

1. DRAINAGE PLAN REQUIRED FOR BUILDING PERMIT SIGN-OFF
2. NO GRADING PROPOSED IN THE REAR WITH THE EXCEPTION  
OF THE REFUSE PAD, CONSEQUENTLY MINIMAL PONDING  
REQUIRED TO INTERCEPT PAD RUNOFF
3. ROUTE THE REMAINING DEVELOPED RUNOFF THRU A  
LANDSCAPED AREA THAT OVERFLOWS TO THE R/W VIA  
THE DRIVEPAD

The undersigned agrees that the above findings are summarized accurately and are only subject to change if further investigation reveals that they are not reasonable or that they are based on inaccurate information.

SIGNED: Red J. Rauque

SIGNED: Jeff Morrison

TITLE: \_\_\_\_\_

TITLE: \_\_\_\_\_

DATE: 4/25/84

DATE: 4/25/84