



City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

DESIGN HYDROLOGY SECTION
123 Central NW, Albuquerque, NM 87102
(505) 766-7644

June 28, 1984

Mr. Claudio Vigil
2340 Alamo SE
Suite 101
Albuquerque, New Mexico

REF DR. PETERSON'S OFFICE ADDITION (J14-D43) BLOK 17 ARMIJO
ADDITION.

Dear Mr. Vigil:

Based on the information provided on your June 14, 1984 submittal of the above referenced site, listed below, you will find certain items that will need to be addressed before final approval is granted.

1. We will need an updated plan reflecting the proposed finish floor to mean sea level.
2. Also we will need the updated plan to reflect your professional stamp, signed and dated.
3. A notation will need to be inserted on the plan addressing the fact that the original ponding areas were eliminated and that they will be reconstructed per plan.
4. We will need verification from City Engineer's Office inspection section that they have inspected the tie in to the existing catch basin on Lomas.

If you have any questions, please feel free to contact me at 766-1044.

Sincerely,

Billy J. Goolsby
Billy J. Goolsby, PE
City/County Flood Plain Admin.

BJM/BJG/cl

MUNICIPAL DEVELOPMENT DEPARTMENT

C. Duayne Sheppard, P.E., City Engineer

ENGINEERING DIVISION

Telephone (505) 766-7467

AN EQUAL OPPORTUNITY EMPLOYER