



City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

DESIGN HYDROLOGY SECTION
123 Central NW, Albuquerque, NM 87102
(505) 766-7644

February 13, 1985

Bob Stamm
Bradbury & Stamm
1217 First, NW
Albuquerque, New Mexico 87102

RE: DOCK & COOLER ADDITION FOR THE BORDEN COMPANY (J-14/D47)

Dear Mr. Stamm:

Based on the information provided on your January 28, 1985 submittal, listed are certain items that will need to be addressed before final approval is given:

1. New information sheet with resubmittal designation.
2. Plan must be prepared, stamped, signed and dated by a New Mexico registered engineer.
3. Flow volumes and rates - calculations showing on-site undeveloped and developed flow volumes and rates.
4. Vicinity map showing location of development in relation to well known landmarks, municipal boundaries and zone atlas map index number.
5. Benchmarks - location, description and elevation of the
 - a. Albuquerque Control Survey Vertical Datum
 - b. Temporary benchmark on-site
6. Location and direction of roof drains.
7. Proposed treatment of developed runoff.
8. Top of curb and flow line spot elevations along bordering streets.

MUNICIPAL DEVELOPMENT DEPARTMENT

C. Dwayne Sheppard, P.E., City Engineer

ENGINEERING DIVISION

Telephone (505) 766-7487

AN EQUAL OPPORTUNITY EMPLOYER

Bob Stamm
February 13, 1985
Page Two of Two

9. Legend - See DPM, Vol. 2, tables 27.3a - 27.3d for recommended standard symbols.

If you have any questions or comments regarding this project, please call me at 766-7644.

Cordially,

A handwritten signature in black ink, appearing to read "Carlos A. Montoya". The signature is fluid and cursive, with a long horizontal stroke extending from the end.

Carlos A. Montoya
City/County Floodplain Administrator

CAM:BJM/bsj