



## *City of Albuquerque*

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

DESIGN HYDROLOGY SECTION  
123 Central NW, Albuquerque, NM 87102  
(505) 766-7644

February 12, 1985

Chris Weiss  
C.T.S., Inc.  
1100-A Alvarado, NE  
Albuquerque, New Mexico 87110

RE: DRAINAGE PLAN FOR SPECIAL SYSTEMS, INC. WAREHOUSE (J-14/D48)  
RECEIVED JANUARY 29, 1985

Dear Mr. Weiss:

Based on City Ordinance, all ponds must drain within 24 hours. Please indicate the type of outlet that will be used on NW pond. Please submit a plat showing the removal of lot lines or a drainage covenant that allows flow across lot lines.

I was unable to find your pre-design sheet in our files, please submit a copy with the next submittal.

If you have any questions or comments, please call me at 766-7644.

Cordially,

Carlos A. Montoya  
City/County Floodplain Administrator

CAM/bsj

MUNICIPAL DEVELOPMENT DEPARTMENT

C. Dwayne Sheppard, P.E., City Engineer

ENGINEERING DIVISION

Telephone (505) 766-7487

AN EQUAL OPPORTUNITY EMPLOYER