


David M.Y. Millikan, P.E.

May 22, 1989



Hill Constructors, Inc. → 664-0332
111 Lomas Boulevard, N.W.
Albuquerque, NM 87102

Attn: Mr. Charles Lloyd

Re: Roof Drain Modifications

Dear Charles:

Enclosed are six sets of the revised drawing sheets C-1, C-2 and C-3 for the Banquest Building at 111 Lomas. The location of discharge for the roof drains from the tower to the Lomas Boulevard right-of-way have been changed to reflect the actual field conditions.

The reduction in outlet size from 12" to 8" has been made based upon the information which you obtained from the plumbing engineer. This size reduction is acceptable to Bernie Montoya at the City Hydrology Department. As you can see, a special junction box and use of the sidewalk culvert are specified. These items have been discussed with Bernie and are acceptable.

Bernie indicated that two sets should be submitted to him to obtain the necessary approval signatures. The other four sets are for your use. Revised mylar sepias have been furnished to R & A Architects if additional copies are needed.

If you have any questions, please call.

Sincerely yours,

A handwritten signature in cursive script that reads "David M.Y. Millikan".

David M.Y. Millikan, P.E.

enclosures

cc: R & A Architects