

x tra



## City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

DESIGN HYDROLOGY SECTION  
123 Central NW, Albuquerque, NM 87102  
(505) 766-7644

October 29, 1985

Mr. Jake Bordenave  
DMJM  
5700 Harper Dr. NE, Suite 280  
Albuquerque, NM 87109

REF: BURGER KING LOMAS (J14-D57)

Dear Mr. Bordenave:

A preliminary review of your submittal for building permit approval has shown that the following information is lacking for this section to begin the review process:

Plan Drawing:

1. Bench Mark description/location.
2. TBM location.
3. Location and/or direction of flow for roof-drains.
4. Please include a legend.

Please provide this information so that we may process your request as expediently as possible.

Cordially,

*Bernie J. Montoya*

City/Design/Hydrology Section

BJM/cl

MUNICIPAL DEVELOPMENT DEPARTMENT

C. Dwayne Sheppard, P.E., City Engineer

ENGINEERING DIVISION

Telephone (505) 766-7467

AN EQUAL OPPORTUNITY EMPLOYER