

CITY OF ALBUQUERQUE
MUNICIPAL DEVELOPMENT DEPARTMENT
ENGINEERING DIVISION/DESIGN HYDROLOGY SECTION

CONFERENCE RECAP

DRAINAGE FILE/ZONE ATLAS PAGE NO.: J-14 DATE: 1/17/86 @ 1:30
PLANNING DIVISION NOS: EPC: _____ DRB: _____
SUBJECT: Bernalillo County Sheriff's Office - Addition
STREET ADDRESS (IF KNOWN): 401 Marquette, NW
SUBDIVISION NAME: Blk 10, Mandrell's Business Add'n.

APPROVAL REQUESTED:

☐ PRELIMINARY PLAT	☐ FINAL PLAT
☐ SITE DEVELOPMENT PLAN	☒ BUILDING PERMIT
☐ OTHER	☐ ROUGH GRADING

	WHO	REPRESENTING
ATTENDANCE:	<u>Jackie McDowell</u>	<u>Chavez-Grievos</u>
	<u>Billy Goolsby</u>	<u>Design Hydrology</u>

FINDINGS:

- ① An approved drainage plan required for building permit sign-off.
- ② Replat required to remove lotlines or appropriate documentation shall be provided.
- ③ An erosion control plan shall be implemented during construction activities to ensure that sediments remain on-site.

The undersigned agrees that the above findings are summarized accurately and are only subject to change if further investigation reveals that they are not reasonable or that they are based on inaccurate information.

SIGNED: <u>Billy G. Goolsby</u>	SIGNED: <u>Jackie McDowell</u>
TITLE: <u>CE Design Hydrology</u>	TITLE: <u>PE Urban Planning</u>
DATE: <u>1/17/86</u>	DATE: <u>1-17-86</u>

****NOTE**** PLEASE PROVIDE A COPY OF THIS RECAP WITH THE DRAINAGE SUBMITTAL