



# City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

DESIGN HYDROLOGY SECTION  
123 Central NW, Albuquerque, NM 87102  
(505) 766-7644

April 14, 1986

Duane Logan  
Logan/Gross  
501 Kinley, NE  
Albuquerque, New Mexico 87102

RE: DRAINAGE PLAN FOR CASA FELICITA APARTMENTS (J-14/D61)  
RECEIVED APRIL 9, 1986

Dear Duane:

A preliminary review of your submittal for Building Permit approval has shown that the following information is lacking for this section to begin the review process:

#### PLAN DRAWING

1. Location of B.M., TBM must be identified as a curb notch or painted.
2. Location and direction of roof drains.
3. More spot elevations to show where developed run-off is supposed to go.
4. Swale detail.
5. Please identify what methods the contractor might use to control erosion.

Please provide this information so that we may process your request as expediently as possible.

Cordially,

*Bernie J. Montoya*  
Bernie J. Montoya, C.E.  
Engineering Assistant

RJM/bsj

MUNICIPAL DEVELOPMENT DEPARTMENT

ENGINEERING DIVISION

Telephone (505) 766-7487

AN EQUAL OPPORTUNITY EMPLOYER