

CITY OF ALBUQUERQUE
MUNICIPAL DEVELOPMENT DEPARTMENT
ENGINEERING DIVISION/DESIGN HYDROLOGY SECTION

CONFERENCE RECAP

DRAINAGE FILE/ZONE ATLAS PAGE NO.: 1-14 DATE: 6/4/86
PLANNING DIVISION NOS: EPC: _____ DRB: _____
SUBJECT: Summit Bank Site
STREET ADDRESS (IF KNOWN): _____
SUBDIVISION NAME: NW corner of 6th & Lomas

APPROVAL REQUESTED:

_____ PRELIMINARY PLAT	_____ FINAL PLAT
_____ SITE DEVELOPMENT PLAN	<u>X</u> BUILDING PERMIT
_____ OTHER	_____ ROUGH GRADING

ATTENDANCE:	WHO	REPRESENTING
	<u>Jackie McDowell</u>	<u>Chavez-Grievess</u>
	<u>Billy J. Goolsby</u>	<u>City Hydrology</u>

FINDINGS:

- Area is an existing developed site. Proposed development will not have any significant effect on the discharge. Therefore no constraints are placed on the site. However, the analysis of the runoff and downstream capacity will still need to be provided.
- An erosion control plan for the period of construction will need to be shown on the plan for permit sign-off.
- Construction ~~design~~ work within City R/W will require a separate document for City Design review & approval (S.D.#19).

The undersigned agrees that the above findings are summarized accurately and are only subject to change if further investigation reveals that they are not reasonable or that they are based on inaccurate information.

SIGNED: <u>Billy J. Goolsby</u>	SIGNED: <u>Jackie McDowell</u>
TITLE: <u>CE Hydrology</u>	TITLE: <u>City Hydrology</u>
DATE: <u>6/4/86</u>	DATE: <u>6/4/86</u>

NOTE PLEASE PROVIDE A COPY OF THIS RECAP WITH THE DRAINAGE SUBMITTAL