


FILE COPY



# City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

Ken Schultz  
Mayor

UTILITY DEVELOPMENT DIVISION  
HYDROLOGY SECTION  
(505) 768-2650

March 2, 1987

Elvidio Diniz  
Resource Technology, Inc.  
2129 Osuna Road, NE Suite 2A  
Albuquerque, New Mexico 87113

RE: REVISED DRAINAGE PLAN FOR AZUELA'S WOODS  
(J-14/D67) RECEIVED FEBRUARY 25, 1987

Dear Elvidio:

Based on the information provided on your resubmittal of February 25, 1987, listed you will find certain items that will need to be addressed prior to final approval:

1. In order to allow that no approved alley grades or improvements to the alley be waived, we will need a more permanent blockade on the south property line other than just a fence (garden wall or curb would be appropriate).
2. We will also need assurance that by the proposed building blocking off-site flows from Lot S, no sediment will be routed towards and into Rosemont Avenue.

If I can be of further assistance, please feel free to call me at 768-2650.

Cordially,

*Bernie J. Montoya*

Bernie J. Montoya, C.E.  
Engineering Assistant

BJH/bsj

PUBLIC WORKS DEPARTMENT

Walter Nickerson, P.E., City Engineer

ENGINEERING GROUP

Telephone (505) 768-2500

AN EQUAL OPPORTUNITY EMPLOYER