

MAR 13 1992



City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

MAR 12 1992

March 4, 1992

Victor Chavez, P.E.
Chavez-Grieves Consulting Engineers
4600-C Montgomery Boulevard, NE
Albuquerque, New Mexico 87109

RE: DRAINAGE PLAN FOR PRESBYTERIAN WAREHOUSE ADDITION
(J-14/D68A) ENGINEER'S STAMP DATED FEBRUARY 17, 1992

Dear Mr. Chavez:

Based on the information provided on your submittal of February 18, 1992, the following concerns must be addressed prior to final approval:

- ✓ 1. Identify what basins are going to each proposed sidewalk culvert and also provide the hydraulics for the culverts.
- ✓ 2. Sign-off block for the S.O. #19 format along with the six notes within the plan drawing.
- ✓ 3. Sidewalk culvert specs do not allow you to sawcut the face of the curb, you must remove the complete stone. Please remove that note from the plan drawing about the sawcut.
- ✓ 4. Two (2) copies of blueprints are required with your resubmittal.
5. Evaluation of your determination for free discharge onto Mountain Road.
INLET IN BROADWAY?

If I can be of further assistance, please feel free to call me at 768-2650.

Cordially,

Bernie J. Montoya
Bernie J. Montoya, C.E.
Engineering Assistant

BJM/bsj
(WP+3225)

PUBLIC WORKS DEPARTMENT

Walter H. Nickerson, Jr., P.E.
Assistant Director Public Works

ENGINEERING GROUP

Telephone (505) 768-2500

AN EQUAL OPPORTUNITY EMPLOYER