

CITY OF ALBUQUERQUE  
MUNICIPAL DEVELOPMENT DEPARTMENT  
ENGINEERING DIVISION/DESIGN HYDROLOGY SECTION

CONFERENCE RECAP

DRAINAGE FILE/ZONE ATLAS PAGE NO.: J14 DATE: 6-30-87  
PLANNING DIVISION NOS: EPC: \_\_\_\_\_ DRB: \_\_\_\_\_  
SUBJECT: The Manger Estate Paving  
STREET ADDRESS (IF KNOWN): Lot 138, 139 & 140 Bk 12  
SUBDIVISION NAME: Arroyo Blvd. Addition

APPROVAL REQUESTED:

\_\_\_\_ PRELIMINARY PLAT  
\_\_\_\_ SITE DEVELOPMENT PLAN  
 OTHER Drainage Permit  
\_\_\_\_ FINAL PLAT  
\_\_\_\_ BUILDING PERMIT  
\_\_\_\_ ROUGH GRADING

ATTENDANCE: WHO REPRESENTING  
Richard Carlson \_\_\_\_\_  
Carl A. Monty \_\_\_\_\_  
\_\_\_\_\_

FINDINGS:

- ① The following items will be needed to obtain paving permit
  - (A) Existing & Proposed contours for paving areas (man see plan)
  - (B) Show any off-site flows if any
  - (C) show how alley interfaces with paving alignment of concrete strip
  - (D) Need professional engineer stamp
- ② (A) Not in a flood zone  
(B) improved 1/4 mi north of site  
(C) can face drainage to alley & street

The undersigned agrees that the above findings are summarized accurately and are on'y subject to change if further investigation reveals that they are not reasonable or that they are based on inaccurate information.

SIGNED: Carl A. Monty  
TITLE: \_\_\_\_\_  
DATE: 6-30-87

SIGNED: Richard Carlson  
TITLE: \_\_\_\_\_  
DATE: 6-30-87

\*\*NOTE\*\* PLEASE PROVIDE A COPY OF THIS RECAP WITH THE DRAINAGE SUBMITTAL