



# City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

Ken Schultz  
Mayor

UTILITY DEVELOPMENT DIVISION  
HYDROLOGY SECTION  
(505) 768-2650

December 9, 1987

Jesse May, P.E.  
Easterling & Associates, Inc.  
5643 Paradise Boulevard, NW  
Albuquerque, New Mexico 87114

RE: DRAINAGE & GRADING PLAN SUBMITTAL OF ALBUQUERQUE REGIONAL  
DETENTION FACILITY RECEIVED NOVEMBER 24, 1987 FOR BUILDING  
PERMIT (J-14/D74)

Dear Jesse:

I have reviewed the above referenced submittal dated November 20, 1987  
and have the following items to be addressed prior to Building Permit  
approval:

1. In the hydrology table, the "C" value is incorrect if  
the existing site is a combination of asphalt and  
building.
2. If the proposed building footprint is the same as the  
perimeter property lines, show the following:
  - a. finish floors of adjacent property building;
  - b. how roof will drain to the single 8" PVC  
drainline shown;
  - c. where parking areas are provided.

PUBLIC WORKS DEPARTMENT

Walter Nickerson, P.E., City Engineer

ENGINEERING GROUP

Telephone (505) 768-2500


AN EQUAL OPPORTUNITY EMPLOYER

Jesse May, P.E.  
December 9, 1987  
Page 2

3. All the drive pads shown are shown as being new, therefore, how is access or parking provided with these drive pads.
4. If the structure is to be multi-story, then shown the finish floor elevations for all the levels and how each will drain.

If you have any questions, please call me at 768-2650.

Cordially,

A handwritten signature in cursive script that reads "Roger A. Green, P.E." with a stylized flourish at the end.

Roger A. Green, P.E.  
C.E./Hydrology Section

xc: Bob Mallory, Architect  
115 Amherst Drive, SE

RAG/bsj