



City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

MAYOR
KEN SCHULTZ

CHIEF
ADMINISTRATIVE OFFICER
GENE ROMO

DEPUTY CAO
DEVELOPMENT & ENTERPRISE SERVICES
LARRY LARRANAGA

DEPUTY CAO
PUBLIC SERVICES
DAN WEAKS

July 13, 1988

Richard Burton
Burton Engineering
Post Office Box 75310 Station 14
Albuquerque, New Mexico 87194

RE: GRADING & PAVING PLAN FOR EL BUENO SAMARITANO CHURCH (J-14/D76)
RECEIVED JULY 5, 1988

Dear Mr. Burton:

Based on the information provided on your submittal of July 5, 1988, listed you will find certain items that will need to be addressed prior to final approval:

1. ✓ Copy of approved vacation for the alley.
2. ✓ Copy of the approved filed replat.
3. ~~3.~~ Verification of first review by DRC for the proposed manhole.
4. Computations showing the capacity of the proposed inlet. *not done*
5. ✓ Elevation at property line must be at least one foot above property line.
6. ✓ More spot elevation needed within the adjacent lots to the south to demonstrate where the flows are going to (at least 25' past the property line).

CHAIRMAN - DEC
Andic Houle

Should you have any questions, please call me at 768-2650.

Cordially,

Bernie J. Montoya, C.E.
Engineering Assistant

BJM/bsj