



City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

KEN SCHULTZ
MAYOR

CLARENCE V. LITHGOW
CHIEF
ADMINISTRATIVE OFFICER

DAN WEAKS
DEPUTY CAO
PUBLIC SERVICES

FRED E. MONDRAGON
DEPUTY CAO
DEVELOPMENT & ENTERPRISE SERVICES

April 13, 1989

Louis W. Gross, P.E.
Louis Gross & Associates, Inc.
925 Sixth Street, NW Suite 3
Albuquerque, New Mexico 87102

RE: REVISED DRAINAGE PLAN FOR OFFICE CONVERSION
911 FORRESTER, NW (J-14/D78) REVISION DATE OF MARCH 21, 1989

Dear Mr. Gross:

Based on the information provided on your resubmittal of March 21, 1989, revisions as indicated are acceptable. Please advise your client that all the developed runoff must exit the site through the existing drive pad.

Please attach a copy of this plan to the construction sets prior to sign-off by Hydrology.

If I can be of further assistance, please feel free to call me at 768-2650.

Cordially,

Bernie J. Montoya
Bernie J. Montoya, C.E.
Engineering Assistant

BJM/bsj
(WP+827)