



KEN SCHULTZ
MAYOR

City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

December 1, 1988

W. Reed Edgel
Consulting Engineer
601 Vassar Drive, NE
Albuquerque, New Mexico 87106

RE: DRAINAGE PLAN FOR AN ADDITION TO STATKUS ENGINES (J-14/D81)
RECEIVED 11/14/88 ENGINEER'S STAMP DATED 11/14/88

Dear Mr. Edgel:

Based on the information provided on your submittal of November 14, 1988, listed are four items that will need to be addressed prior to approval.

1. Finish floor elevation to full mean sea level designation of proposed building and existing.
2. Location, description and elevation of:
 - a. ASC bench mark used;
 - b. T.B.M. located on site.
3. Roof drainage of proposed building must be routed towards the concrete paved area.
4. Few spot elevations to demonstrate how the runoff will be routed towards Aspen Street.

If I can be of further assistance, please call me at 768-2650.

Cordially,

Roger A. Green
For Bernie J. Montoya, C.E.
Engineering Assistant

BJM/bsj
(WP+944)