

Pre-Design Investigation
(Additions)

DATE 11-14-88

ADDRESS 1623 Los Tomases ZONE ATLAS # J14/D81

LEGAL DESCRIPTION _____


OWNER _____

ARCHITECT/ENGINEER _____

LOT SIZE _____

ZONING _____

PROPOSED DEVELOPMENT 900# ADDN.



	YES	NO	NA	COMMENTS
FLOOD HAZARD AREA		B		
PART OF AN APPROVED REPORT		✓		
CONSTRUCTION PLANS ON MICRO-FILM		✓		
FIELD INSPECTION	✓			

COMMENTS:

EAST HALF OF ADDN. DRAINS ONTO EXISTING CONCRETE

DRIVEWAY EXITING SITE THRU DRIVEWAY INTO ASPHALT

WEST HALF OF ADDN WILL NEED ROOF GUTTER TO

CHANNEL WATER INTO RIGHT-OF-WAY & NOT INTO ADJACENT PROP.

DRAINAGE REQUIREMENTS:

