

FILE COPY



City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

August 10, 1990

Frank Lovelady
Lovelady & Associates
7408 Morrow, NE
Albuquerque, New Mexico 87110

RE: DRAINAGE PLAN FOR AN ADDITION TO MARTIN J. VIGIL BUILDING
(J-14/D91) ENGINEER'S STAMP DATED JULY 31, 1990

Dear Mr. Lovelady:

Based on the information provided on your submittal of July 31, 1990, listed are some concerns that will need to be addressed prior to approval.

1. 0.002 ft/ft slope is not adequate to drain the runoff. A minimum of .5% slope is required.
2. If the alley is paved and you can demonstrate that it will carry the runoff toward the closest improved public street. Then you may want to design for this concept.

If I can be of further assistance, please feel free to call me at 768-2650.

Cordially,

Fred J. Aguirre, P.E.
Hydrologist

BJM:FJA/bsj
(WP+2086)

PUBLIC WORKS DEPARTMENT

Walter H. Nickerson, Jr., P.E.
Assistant Director Public Works

ENGINEERING GROUP

Telephone (505) 768-2500

AN EQUAL OPPORTUNITY EMPLOYER