

CITY OF ALBUQUERQUE
PUBLIC WORKS DEPARTMENT
UTILITY DEVELOPMENT DIVISION/HYDROLOGY SECTION

PRE-DESIGN CONFERENCE

DRAINAGE FILE/ZONE ATLAS PAGE NO.: J14-D92 DATE: 3/1/93

EPC NO.: _____ DRB NO.: _____ ZONE: _____

SUBJECT: _____

STREET ADDRESS: _____

LEGAL DESCRIPTION: TRACT 280

APPROVAL REQUESTED: _____ PRELIMINARY PLAT _____ FINAL PLAT
_____ SITE DEVELOPMENT PLAN ☒ BUILDING PERMIT
_____ GRADING/PAVING PERMIT _____ OTHER

ATTENDANCE:

WHO	REPRESENTING
<u>John Sanchez</u>	<u>Right Way Roofing</u>
<u>Bernie J. Montoya</u>	<u>CO-A.</u>

FINDINGS:

1. Drainage plan per D.P.M. guidelines prior to Building Permit release.
2. Site must be brought back into compliance for flood control.
3. Ponding area must be controlled release.
4. _____

The undersigned agrees that the above findings are summarized accurately and are only subject to change if further investigation reveals that they are not reasonable or that they are based on inaccurate information.

SIGNED: _____ SIGNED: _____

TITLE: _____ TITLE: _____

DATE: _____ DATE: _____

****NOTE**** PLEASE PROVIDE A COPY OF THIS PRE-DESIGN FORM WITH THE DRAINAGE SUBMITTAL.