

July 29, 2005

Bradley L. Bingham P.E.  
Principal Engineer, Planning Department  
P.O. Box 1293  
Albuquerque, New Mexico 87103

**RE: OFFICE BUILDING @ 802 LOMAS BLVD. N.E. (J14-D94)**

Dear Mr. Bingham:

This letter is in response to your comment letter dated July 7, 2005:

1. Provide inverts for the proposed sidewalk culvert. *Invert has been providing on the plan drawing.*
2. Call out City of Albuquerque Standard Drawings for the proposed sidewalk culvert, sidewalk and curb and gutter. *City standard spec. Numbers are shown on the plan drawing.*
3. Verify flow direction along Kelleher Avenue. *Flow arrow has been rotated to indicate the correct flow direction on Kelleher Avenue. Included is a schematic of the existing infrastructure in the area. The developed flows will enter the existing catchbasin at the intersection of Kelleher and fruit Avenue.*

If I can be of further assistance, please feel free to call me at 250-7719.

Sincerely

  
Bernie J. Montoya C.E.

